



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

Water Quality Testing Results for Sodium

The Acton Water District conducts annual sampling of all wells for sodium. The most recent results entering our distribution system are listed in the table below.

| Date | Source | Concentration mg/L |
|-------------|--------------------|-------------------------------|
| 5/19/10 | ASSABET WTP | 28 |
| 4/28/10 | CLAPP/WHITCOMB WTP | 28 |
| 4/27/10 | SCHOOL STREET WTP | 29 |
| 4/15/10 | NORTH ACTON WTP | 22 |
| 6/18/10 | CONANT I WELL | 10.1 |
| 4/15/10 | CONANT II WELL | 16 |

Although sodium does not have a maximum contaminant level, the Department of Environmental Protection does have a guideline of 20 milligrams per liter (mg/L) for sensitive individuals, such as those on very salt-restricted diets. Sodium levels in drinking water vary considerably from well to well and month to month. For the most accurate data on sodium levels at your home, an individual tap sample would be necessary.