

Acton Water District - PWS 2002000  
 Summary of Treated Water Per- and Polyfluoroalkyl Substances (PFAS)

Sample Location	Sample Date						
	January 13, 2020	March 2, 2020	March 26, 2020	April 2, 2020	April 27, 2020	April 28, 2020	June 2, 2020
Clapp/Whitcomb WTP				ND	ND		
Conant 1			7.72		10.75		
Conant 2			10.84			10.53	
North Acton WTP				48.33		41.85	
South Acton WTP	20.85	20.98					22.5

Notes:

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection Guideline of 20 ppt or ng/L