

Acton Water District - PWS 2002000
 Summary of Treated Water Per- and Polyfluoroalkyl Substances (PFAS)

Sample Location	Sample Date														
	January 13, 2020	March 2, 2020	March 26, 2020	April 2, 2020	April 27, 2020	April 28, 2020	June 2, 2020	July 10, 2020	July 13, 2020	August 31, 2020	September 10, 2020	October 26, 2020	November 2, 2020	November 18, 2020	November 30, 2020
Clapp/Whitcomb WTP				ND	ND				ND			ND			
Conant 1			7.72		9.89			17.99		22.6			25.7		
Conant 2			10.84			7.86		25.61		26.4				25.13	
North Acton WTP				47.24		40.36					14.04				16.33
South Acton WTP	20.85	21.03					22.5		18.78	19.4			18.08		

Notes:

WTP = Water Treatment Plant

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection Guideline of 20 ppt or ng/L

North Acton WTP remains off and was sampled on September 10 and November 30, 2020 with the water not being served to customers