

Acton Water District - PWS 2002000  
 Summary of Treated Water Per- and Polyfluoroalkyl Substances (PFAS) 2023

Sample Date	Sample Location			
	Clapp/Whitcomb WTP	Central Acton WTP	North Acton WTP	South Acton WTP
January 13, 2023	Not Sampled	25.8	Not Sampled	17.5
January 27, 2023	Not Sampled	Not Sampled	18	Not Sampled
February 21, 2023	Not Sampled	Not Sampled	20.1	15.4
February 27, 2023	Not Sampled	10.7	Not Sampled	Not Sampled

Notes:

WTP = Water Treatment Plant

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Not Sampled = PFAS samples are not collected at each WTP on the same date or when a WTP is not producing water for consumption

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection (MassDEP) Maximum Contaminant Level (MCL) of 20 ppt or ng/L

All treated water data is shared with consumers to be transparent. Not all of the data presented here will meet MassDEP data acceptance standards.