

Acton Water District - PWS 2002000  
 Summary of Treated Water Per- and Polyfluoroalkyl Substances (PFAS) 2024

Sample Date	Sample Location			
	Clapp/Whitcomb WTP	Central Acton WTP	North Acton WTP	South Acton WTP
January 11, 2024	Not Sampled	Not Sampled	16.9	15.1
January 25, 2024	Not Sampled	6.4	Not Sampled	Not Sampled
February 7, 2024	Not Sampled	6.5	Not Sampled	14.4
March 6, 2024	Not Sampled	6.2	Not Sampled	11.6
March 27, 2024	Not Sampled	Not Sampled	16.1	Not Sampled
April 5, 2024	Not Sampled	Not Sampled	20.7	14.7

Notes:

WTP = Water Treatment Plant

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Not Sampled = PFAS samples are not collected at each WTP on the same date or when a WTP is not producing water for consumption

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection (MassDEP) Maximum Contaminant Level (MCL) of 20 ppt or ng/L

All treated water data is shared with consumers to be transparent. Not all of the data presented here will meet MassDEP data acceptance standards.