

Sample Date	Sample Location			
	Clapp/Whitcomb WTP	Conant 1	North Acton WTP	South Acton WTP
January 20, 2021	ND	Not Sampled	Not Sampled	19.7
January 27, 2021	Not Sampled	16.3	19.23*	Not Sampled
February 16, 2021	Not Sampled	18.8	19.8*	Not Sampled
February 22, 2021	Not Sampled	Not Sampled	22.8	16.8
March 8, 2021	Not Sampled	Not Sampled	19.9	Not Sampled
March 15, 2021	Not Sampled	Not Sampled	Not Sampled	15.9
March 30, 2021	Not Sampled	15.6	Not Sampled	Not Sampled
April 13, 2021	Not Sampled	21.1	30.23	Not Sampled
April 21, 2021	Not Sampled	Not Sampled	Not Sampled	22.49
April 30, 2021	ND	Not Sampled	Not Sampled	Not Sampled

Notes:

WTP = Water Treatment Plant

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Not Sampled = PFAS samples are not collected at each WTP on the same date

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection (MassDEP) Maximum Contaminant Level (MCL) of 20 ppt or ng/L

* Facility was not delivering water to customers at time of sampling

All treated water data is shared with consumers to be transparent. Not all of the data presented here will meet MassDEP data acceptance standards.